



<u>PERFORMANCE</u>

| HEATING CAPACITY (ABOVE 5°F) [BTUH] | 123,200 |
|---|---------|
| NOMINAL OUTPUT [GPM @ 100°F LIFT] | 2.5 |
| MAX. DAILY OUTPUT [GAL./DAY @ 100°F LIFT] | 2,365 |
| MAX. DAILY RUNTIME [HOURS / DAY] | 16 |
| AIRFLOW [CFM] | 4,800 |
| EXTERNAL STATIC PRESSURE [INH2O] | 0 |
| SOUND LEVEL [dB(A)] | 40 |
| *MAX. PIPE LENGTH TO STORAGE TANKS [FT.] | 55 |
| *MAX. VERTICAL DISTANCE TO STORAGE TANK [FT.] | 20 |
| REFRIGERANT TYPE | R-744 |
| TOTAL CHARGE [OZ.] | 203.2 |
| MAX. SYSTEM WATER PRESSURE [PSI] | 75 |
| HEAT TRACE CAPACITY [W/FT.] (OPTIONAL) | 8 |
| | |

^{*}LIMITED BY HEAT PUMP INTERNAL CIRCULATOR PUMP AVAILABLE HEAD

ELECTRICAL

| VOLTAGE/PHASE/FREQ. | 208V/3Ø/60Hz |
|---------------------|--------------|
| FLA [A] | 46.2 |
| MCA [A] | 61.3 |
| MOCP [A] | 70 |

WEIGHT

| DRY WEIGHT, INSTALLED* [LBS.] | 2,250 |
|-------------------------------|-------|
|-------------------------------|-------|

^{*}APPROX.

COMPONENT & CONSTRUCTION DETAIL

| 20-MESH WYE-STRAINER LOCATED ON COLD SUPPLY |
|---|
| INDIVIDUAL HEAT PUMP ISOLATION AND CHECK VALVES |
| HEAT TRACE ON PIPING AND CONDENSATE DRAIN PANS (OPTIONAL) |
| POWDER-COATED STEEL FRAME |
| 1-1/2" PIPE INSULATION |
| TYPE K COPPER PIPING |
| ONBOARD STAGING CONTROLLER |
| UL508A PANEL |

MOUNTING ANCHORS

| DIAMETER | 1/2" |
|-------------------------------|-------|
| UPLIFT/PULLOUT CAPACITY [lbf] | 1,000 |
| SHEAR CAPACITY [lbf] | 750 |
| NO. OF ANCHORS REQUIRED | 8 |

FIELD CONNECTIONS

| | LINES A,B,C | | |
|------------|-------------------|-------------------------|--|
| ELECTRICAL | NEUTRAL | | |
| | GROUND | | |
| PLUMBING | HOT WATER OUTLET | 1-1/2" MNPT | |
| | COLD WATER SUPPLY | 1-1/2" MNPT | |
| | CONDENSATE DRAINS | (3) 1/2" COPPER STUB | |

SMALL PLANET SUPPLY TUMWATER, WA

DROPLET8-RH SUBMITTAL (TECHNICAL DATASHEET)

SIZE DWG. NO. **B** 003-00011

SCALE: NTS

SHEET 3 OF 4

